



**PUBLIC WORKS DEPARTMENT (B & R), HARYANA**

Office of Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad.  
Tele – 0129-2288187



Memo No. 5977 Dated 28/8/24  
To

The Principal,  
Vidyasagar International School,  
Gharora(Manjhawali Road), Tigaon,  
Faridabad.

**Subject:-** Regarding letter for providing NOC for building stability safety certificate.


**Reference:-** Your office letter No. VIS/2024-25/011 dated 14.08.2024

In this connection, it is submitted that the above said school building was inspected by the Sub Divisional Engineer, Provincial Sub Division No.2 PWD B&R Br., Faridabad along with Sh. Sardar Singh, J.E. on dated 24.08.2024. The school building having ground floor, first floor and 2nd floor & 3rd floor The inspection fees of site is deposited by the applicant vide GRN No 108486609 dated 22/8/24 amounting to Rs. 10000/-.

The building is constructed with frame structure having RCC column, beams slab and 9" thick load bearing outer walls. The structure stability certificate has been also enclosed herewith which is issued by N.K Design Collective, M.Tech Structure Eng. HUDA (Regd) Govt approved project Management structural Design & quantity estimation 183/10 HBC Faridabad vide reference no. 0397 dated 06.08.2024. The fire fighting in school building is not installed.

Keeping in view of all the circumstance the building of Vidyasagar International School, Gharora Manjhawali road Faridabad (Haryana) seems to be safe. The Periodical inspection must be insured.

DA/Nil

  
Executive Engineer  
Provincial Division  
PWD B&R Br., Faridabad

Endst.No.

Dated:-

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.2, PWD, B&R, Br., Faridabad for information and necessary action with reference to his office Memo No. 621 Dated 27.08.2024

DA/Nil

  
Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

Miss private school